

Statement of Compliance

The FirePro FP-08450 Fire Control Panel is a combined detection and extinguishing system, and is compliant for use in marine applications under Australian Safety Maritime Authority – National Standards for Commercial Vessels – C4 Section 4 (July 2018).

The system specifically complies under Table 14: Acceptable Standards for Fixed Fire Extinguishing Systems – Aerosol Fixed Fire Extinguishing Systems - ISO 15779.

The Fire Indicator Panel incorporates:

- 2x Detection circuits
- 1x Extinguishing Discharge circuit
- 1x Siren/Strobe circuit
- Manual Activation
- Fault Monitoring system – all circuits
- Isolation Function

This compliance covers the components list, installation and commissioning as described in the manual "Fire Detection and Activation System Model 08450 Rev 2.3".

Aerosol Product Certification

Compliance to ISO 15779 requires the Aerosol Product to be listed or certified by an internationally recognised fire protection systems test and certification organisation.

FirePro Aerosol Generators are certified by



Ray Mergard
Managing Director



Phil Morris
Director