

Kitemark™ Certificate

This is to certify that:

FirePro Systems Ltd
8 Faleas Str.
Agios Athanasios Industrial Area
Limassol
CY-4101
Cyprus

Holds Certificate Number:

KM 738886

In respect of:

BS EN 15276
Condensed aerosol extinguishing systems

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.



For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2021-04-14

Latest Issue: 2022-09-14

Effective Date: 2022-09-14

Expiry Date: 2024-04-13



Page: 1 of 3

Kitemark™ Certificate

No. KM 738886

Model No	Description	Branded As
FP-20SE	Condensed Aerosol Generator; 20g of solid aerosol forming compound, Cylinder - Stainless Steel Housing, Electrical Activation, Efficiency 60%	FirePro
FP-20T	Condensed Aerosol Generator; 20g of solid aerosol forming compound, Cylinder - Stainless Steel Housing, Electrical Activation, Efficiency 70%	FirePro
FP-20TH	Condensed Aerosol Generator; 20g of solid aerosol forming compound, Cylinder - Stainless Steel Housing, Thermal Activation, Efficiency 70%	FirePro
FP-40S	Condensed Aerosol Generator; 40g of solid aerosol forming compound, Cylinder - Stainless Steel Housing, Electrical Activation, Efficiency 61%	FirePro
FP-40T	Condensed Aerosol Generator; 40g of solid aerosol forming compound, Cylinder - Stainless Steel Housing, Thermal / Electrical Activation, Efficiency 62%	FirePro
FP-80S	Condensed Aerosol Generator; 80g of solid aerosol forming compound, Cylinder - Stainless Steel Housing, Electrical Activation, Efficiency 59%	FirePro
FP-80T	Condensed Aerosol Generator; 80g of solid aerosol forming compound, Cylinder - Stainless Steel Housing, Thermal / Electrical Activation, Efficiency 60%	FirePro
FP-100S	Condensed Aerosol Generator; 100g of solid aerosol forming compound, Cylinder - Stainless Steel Housing, Thermal / Electrical Activation, Efficiency 61%	FirePro
FP-200S	Condensed Aerosol Generator; 200g of solid aerosol forming compound, Cylinder - Stainless Steel Housing, Thermal / Electrical Activation, Efficiency 59%	FirePro
FP-500S	Condensed Aerosol Generator; 500g of solid aerosol forming compound, Cylinder - Stainless Steel Housing, Thermal / Electrical Activation, Efficiency 66%	FirePro
FP-1200	Condensed Aerosol Generator; 1200g of solid aerosol forming compound, Box - Red Coated Steel Housing, Electrical Activation, Efficiency 63%	FirePro
FP-1200T	Condensed Aerosol Generator; 1200g of solid aerosol forming compound, Box - Red Coated Steel Housing, Thermal / Electrical Activation, Efficiency 63%	FirePro
FP-1200S	Condensed Aerosol Generator; 1200g of solid aerosol forming compound, Box - Stainless Steel Housing, Electrical Activation, Efficiency 63%	FirePro
FP-1200TS	Condensed Aerosol Generator; 1200g of solid aerosol forming compound, Box - Stainless Steel Housing, Thermal / Electrical Activation, Efficiency 63%	FirePro
FP-2000	Condensed Aerosol Generator; 2000g of solid aerosol forming compound, Box - Red Coated Steel Housing, Electrical Activation, Efficiency 60%	FirePro

First Issued: 2021-04-14

Latest Issue: 2022-09-14

Effective Date: 2022-09-14

Expiry Date: 2024-04-13

Page: 2 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.

Kitemark™ Certificate

No. KM 738886

Model No	Description	Branded As
FP-2000T	Condensed Aerosol Generator; 2000g of solid aerosol forming compound, Box - Red Coated Steel Housing, Thermal / Electrical Activation, Efficiency 60%	FirePro
FP-2000S	Condensed Aerosol Generator; 2000g of solid aerosol forming compound, Box - Stainless Steel Housing, Electrical Activation, Efficiency 60%	FirePro
FP-2000TS	Condensed Aerosol Generator; 2000g of solid aerosol forming compound, Box - Stainless Steel Housing, Thermal / Electrical Activation, Efficiency 60%	FirePro
FP-3000	Condensed Aerosol Generator; 3000g of solid aerosol forming compound, Box - Red Coated Steel Housing, Electrical Activation, Efficiency 61%	FirePro
FP-3000T	Condensed Aerosol Generator; 3000g of solid aerosol forming compound, Box - Red Coated Steel Housing, Thermal / Electrical Activation, Efficiency 61%	FirePro
FP-3000S	Condensed Aerosol Generator; 3000g of solid aerosol forming compound, Box - Stainless Steel Housing, Electrical Activation, Efficiency 61%	FirePro
FP-3000TS	Condensed Aerosol Generator; 3000g of solid aerosol forming compound, Box - Stainless Steel Housing, Thermal / Electrical Activation, Efficiency 61%	FirePro
FP-4200T	Condensed Aerosol Generator; 4200g of solid aerosol forming compound, Box - Red Coated Steel Housing, Thermal / Electrical Activation, Efficiency 60%	FirePro
FP-4200TS	Condensed Aerosol Generator; 4200g of solid aerosol forming compound, Box - Stainless Steel Housing, Thermal / Electrical Activation, Efficiency 60%	FirePro
FP-5700	Condensed Aerosol Generator; 5700g of solid aerosol forming compound, Box - Red Coated Steel Housing, Electrical Activation, Efficiency 59%	FirePro
FP-5700T	Condensed Aerosol Generator; 5700g of solid aerosol forming compound, Box - Red Coated Steel Housing, Thermal / Electrical Activation, Efficiency 59%	FirePro
FP-5700S	Condensed Aerosol Generator; 5700g of solid aerosol forming compound, Box - Stainless Steel Housing, Thermal / Electrical Activation, Efficiency 59%	FirePro
FP-5700TS	Condensed Aerosol Generator; 5700g of solid aerosol forming compound, Box - Stainless Steel Housing, Thermal / Electrical Activation, Efficiency 59%	FirePro

Aerosol Generating Fire Extinguishing System Units are certified to BS EN 15276-1; 2019

First Issued: 2021-04-14

Latest Issue: 2022-09-14

Effective Date: 2022-09-14

Expiry Date: 2024-04-13

Page: 3 of 3

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.