

CERTIFICATE OF COMPLIANCE

Certificate Number E525880
Report Reference E525880-20220414
Date 2022-April-15

Issued to: FIREPRO SYSTEMS LTD
8 Faleas Str
Limassol CY 4101 CY

**This is to certify that
representative samples of** FIXED CONDENSED AEROSOL EXTINGUISHING
SYSTEM UNITS FOR USE IN HAZARDOUS LOCATIONS
See Addendum Page for Product Designation(s).

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 121201, Nonincendive Electrical Equipment for Use in
Class I and II, Division 2 and Class III, Divisions 1 and 2
Hazardous (Classified) Locations


CSA C22.2 No. 213-17, Nonincendive Electrical Equipment
for Use in Class I and II, Division 2 and Class III, Divisions 1
and 2 Hazardous (Classified) Locations

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE


Certificate Number E525880
Report Reference E525880-20220414
Date 2022-April-15

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Models:

Aerosol-generating Fire Extinguishing System Units, for use in Class I, Division 2, Groups A, B, C and D, Hazardous Locations.

FirePro condensed aerosol generator, Part No.:	FP-20SE, FP-20T
FirePro condensed aerosol generator, Part No.:	FP-40S, FP-40T
FirePro condensed aerosol generator, Part No.:	FP-80S, FP-80T
FirePro condensed aerosol generator, Part No.:	FP-100S, FP-100T
FirePro condensed aerosol generator, Part No.:	FP-200S, FP-200T
FirePro condensed aerosol generator, Part No.:	FP-500S, FP-500T
FirePro condensed aerosol generator, Part No.:	FP-1200, FP-1200S, FP-1200T, FP-1200TS
FirePro condensed aerosol generator, Part No.:	FP-2000, FP-2000S, FP-2000T, FP-2000TS
FirePro condensed aerosol generator, Part No.:	FP-3000, FP-3000S, FP-3000T, FP-3000TS
FirePro condensed aerosol generator, Part No.:	FP-4200, FP-4200S, FP-4200T, FP-4200TS
FirePro condensed aerosol generator, Part No.:	FP-5700, FP-5700S, FP-5700T, FP-5700TS



Bruce Mahrenholz, Director North American Certification Program

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE


Certificate Number E525880
Report Reference E525880-20220414
Date 2022-April-15

Mounting bracket, 20g, Part No.:	C20BR
Mounting bracket, 40, 80g, Part No.:	C4080BRS1, C4080BRS2, C4-8RBR
Mounting bracket, 100, 200, 500g, Part No.:	C1-2-5ABS, C1-2-5RBR, C1-2-5RB, C1-2-5AS/C-1-2-5U
Mounting bracket, 2000, 3000, 1200g, Part No.:	B122030BRKT, B122030BRKT/A
Mounting bracket, 4200, 5700g, Part No.:	BABRKTS
Design, Installation, Operation and Maintenance Manual, dated YYYY-MM-DD:	Ex 6960, Version 1.0, Rev. 8, dated March 2022

For Class A surface burning and Class B and C category hazards; for use in hazardous (classified) locations.
Temperature range -65°F(-54°C) to +130°F(+54°C).

Aerosol-generating Fire Extinguishing System Units, for use in Class I, Division 2, Groups A, B, C and D, Hazardous Locations.

FireBan condensed aerosol generator, Part No.:	FBN-20SE, FBN-20T
FireBan condensed aerosol generator, Part No.:	FBN-40S, FBN-40T
FireBan condensed aerosol generator, Part No.:	FBN-80S, FBN-80T
FireBan condensed aerosol generator, Part No.:	FBN-100S, FBN-100T
FireBan condensed aerosol generator, Part No.:	FBN-200S, FBN-200T
FireBan condensed aerosol generator, Part No.:	FBN-500S, FBN-500T



Bruce Mahrenholz, Director North American Certification Program

UL LLC




Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number E525880
Report Reference E525880-20220414
Date 2022-April-15

FireBan condensed aerosol generator, Part No.:	FBN-1200, FBN-1200S, FBN-1200T, FBN-1200TS
FireBan condensed aerosol generator, Part No.:	FBN-2000, FBN-2000S, FBN-2000T, FBN-2000TS
FireBan condensed aerosol generator, Part No.:	FBN-3000, FBN-3000S, FBN-3000T, FBN-3000TS
FireBan condensed aerosol generator, Part No.:	FBN-4200, FBN-4200S, FBN-4200T, FBN-4200TS
FireBan condensed aerosol generator, Part No.:	FBN-5700, FBN-5700S, FBN-5700T, FBN-5700TS
Mounting bracket, 20g, Part No.:	C20BR
Mounting bracket, 40, 80g, Part No.:	C4080BRS1, C4080BRS2, C4-8RBR
Mounting bracket, 100, 200, 500g, Part No.:	C1-2-5ABS, C1-2-5RBR, C1-2-5RB, C1-2-5AS/C-1-2-5U
Mounting bracket, 2000, 3000, 1200g, Part No.:	B122030BRKT, B122030BRKT/A
Mounting bracket, 4200, 5700g, Part No.:	BABRKTS
Design, Installation, Operation and Maintenance Manual, dated YYYY-MM-DD:	Ex 6960, Version 1.0, Rev. 2, dated March 2022

For Class A surface burning and Class B and C category hazards; for use in hazardous (classified) locations. Temperature range -65°F(-54°C) to +130°F(+54°C).



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

