FirePro. Reinventing Fire Suppression	MED Marine Calculation								2/09/	2020 Rev: 21.4		
Vessel Name	Sample Calculation	Model	L2 (mm)	L3 (mm)	Stream (mm)	Agent Qty	Concer Primary	tration Secondary	Primary Quantity	Secondary Quantity		
Risk Area	Sample	FP-0020	0	100	300	12	-	-				
Class / Flag State	Sample	FP-0040	0	100	1200	24	-	-				
	✓ Class A ✓ Class B ✓ Class E ☐ Class D ☐ Class F	FP-0080	0	100	2000	47	-	-				
		FP-0100	0	100	1000	61	-	-				
	Length Width Height Not Used	FP-0200	100	300	1500	118	-	-				
GROSS DIMENSIONS	4.00 \times 3.00 \times 2.50 = m^3	FP-0500	200	500	2500	330	-	-				
	Deductions from Gross Volume - m ³ = m ³	FP-1200	200	1200	3500	756	-	-				
		FP-2000	200	1200	3500	1,200	-	-				
Lea	akage Allowance without additional Agent = - m ²	FP-3000	700	1700	4000	1,830	3,660	-	2			
	NET Volume used for Calculation = 30.00 m ³	FP-5700	800	1800	8000	3,363	-	-				
PRIMARY AGENT DISCHARGE = 3,600 g			Total Concentration 3,660 - Required Concentration 3,600 - % Required Concentration 101%									
Secondary Agent Discharge = Not Required				✓ Design Calculation has been Confirmed								
			FirePro Units have suitable STREAM length for Risk Area Coverage									
	✓ Leakage compensation made in Primary Discharge											
MED Design Notes			☐ Additional HOLD time Required for the risk									
Pre-Engineered Design Calculation CALCULATION OF VOLUME: Any Objects that occupy volume within the protected space SHOULD BE subtracted from the gross volume of the space. These items should exclude any combustible items. (MSC 1/Circ 1270, Chapter 11.3) AMSA and SOLAS. Minimum Extinguishing Factors (mef) 120 X 1 = 120												
	rance required where the temperature of the discharge is less than 200° C											