



24th October 2019.

Rivtow Marine Qld
Half Tide Tug Harbour,
The Esplanade,
Mackay, 4740.

Attn: Mr. Rob Mason.

Description - McEwen 15M Line Handler Vessel.

Reference: **Customer order # - Email Suppliers invoice # - 300946**

CERTIFICATE OF COMPLIANCE

This is to Certify that the following annual service was completed on board the vessel as per the manufacture's maintenance schedule.

1. FirePro aerosol fire suppression system. Annual inspection & test discharge was completed.
2. Engine room – 2 x 2000g generators – test discharge was completed.
3. Model 8450 control panel was replaced & tested.
4. Generators & panel – passed.
5. Separate Control panel & thermal detection tested & passed.
6. Audio visual alarms for both systems – passed.
7. The risk has not changed & the original design calculation does not require to be modified.

Ray Mergard

A handwritten signature in black ink, appearing to read 'Ray Mergard', written over a faint, larger version of the same signature.

Director & QA Manager