

Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	FirePro Systems Limited	Client ID	106800
Company Other Name	FirePro	Type of Certification	Product Certification; System 5
Certification Standard	AS 5062-2022 : Fire prevention and protection for mobile and transportable equipment		
Scheme	Global-Mark Product Conformance Scheme		
Certification Review Date	24/09/2025	Certification Expiry Date	6/11/2030
Certificate Issue Date	27/11/2020	Certificate Last Update Date	7/03/2026

APPROVED COMPANY/SITE ADDRESS(ES):
8 Faleas Street, Agios Athanasios Industrial Area Limassol - CY-4101 Cyprus

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager

Unique Certificate Code: **9D8AB2DD95CF125647258DB20007884E**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®



WWW.JASANZ.ORG/REGISTER



Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
FP-20SE	FP-20SE	FirePro	Condensed Aerosol Generator: Generator Wt: 310gr, Aerosol agent Wt: 20gr, Stainless steel housing, Discharge time: 5 - 10 Secs, Two direction outlet, Fire Class: A, B, E	13/10/2015
FP-20T	FP-20T	FirePro	Condensed Aerosol Generator: Generator Wt: 310gr, Aerosol agent Wt: 20gr, Discharge time: 3-6 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-40S	FP-40S	FirePro	Condensed Aerosol Generator: Generator Wt: 610gr, Aerosol agent Wt: 40gr, Discharge time: 5 - 10 Secs, Two direction outlet, Fire Class: A, B, E	13/10/2015
FP-40T	FP-40T	FirePro	Condensed Aerosol Generator: Generator Wt: 585gr, Aerosol agent Wt: 40gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-80S	FP-80S	FirePro	Condensed Aerosol Generator: Generator Wt: 870gr, Aerosol agent Wt: 80gr, Discharge time: 5 - 10 Secs, Two direction outlet, Fire Class: A, B, E	13/10/2015
FP-80T	FP-80T	FirePro	Condensed Aerosol Generator: Generator Wt: 840gr, Aerosol agent Wt: 80gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-100S	FP-100S	FirePro	Condensed Aerosol Generator: Generator Wt: 1370gr, Aerosol agent Wt: 100gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-100T	FP-100T	FirePro	Condensed Aerosol Generator: Generator Wt: 1540gr, Aerosol agent Wt: 100gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	15/04/2024
FP-100SD	FP-100SD	FirePro	Condensed Aerosol Generator: Generator Wt: 1430gr, Aerosol agent Wt: 100gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	1/11/2025
FP-100SE	FP-100SE	FirePro	Condensed Aerosol Generator: Generator Wt: 1370gr, Aerosol agent Wt: 100gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	1/11/2025
FP-200S	FP-200S	FirePro	Condensed Aerosol Generator: Generator Wt: 1840gr, Aerosol agent Wt: 200gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-200T	FP-200T	FirePro	Condensed Aerosol Generator: Generator Wt: 2010gr, Aerosol agent Wt: 200gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	15/02/2024
FP-200SD	FP-200SD	FirePro	Condensed Aerosol Generator: Generator Wt: 1870gr, Aerosol agent Wt: 200gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	1/11/2025
FP-200SE	FP-200SE	FirePro	Condensed Aerosol Generator: Generator Wt: 1805gr, Aerosol agent Wt: 200gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	1/11/2025
FP-500S	FP-500S	FirePro	Condensed Aerosol Generator: Generator Wt: 3340gr, Aerosol agent Wt: 500gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-500T	FP-500T	FirePro	Condensed Aerosol Generator: Generator Wt: 3440gr, Aerosol agent Wt: 500gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	15/02/2024



Certification Manager

Jane Hoban



global-mark®

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
FP-500SD	FP-500SD	FirePro	Condensed Aerosol Generator: Generator Wt: 3335gr, Aerosol agent Wt: 500gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	1/11/2025
FP-500SE	FP-500SE	FirePro	Condensed Aerosol Generator: Generator Wt: 3270gr, Aerosol agent Wt: 500gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	1/11/2025
FP-1200	FP-1200	FirePro	Condensed Aerosol Generator: Generator Wt: 10900gr, Aerosol agent Wt: 1200gr, Discharge time: 15-20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-1200S	FP-1200S	FirePro	Condensed Aerosol Generator: Generator Wt: 10900gr, Aerosol agent Wt: 1200gr, Discharge time: 15-20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-1200T	FP-1200T	FirePro	Condensed Aerosol Generator: Generator Wt: 10900gr, Aerosol agent Wt: 1200gr, Thermal Activation, Discharge time: 15-20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-1200TS	FP-1200TS	FirePro	Condensed Aerosol Generator: Generator Wt: 10900gr, Aerosol agent Wt: 1200gr, Thermal Activation, Discharge time: 15-20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-2000	FP-2000	FirePro	Condensed Aerosol Generator: Generator Wt: 15500gr, Aerosol agent Wt: 2000gr, Discharge time: 15-20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-2000S	FP-2000S	FirePro	Condensed Aerosol Generator: Generator Wt: 15500gr, Aerosol agent Wt: 2000gr, Discharge time: 15-20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-2000T	FP-2000T	FirePro	Condensed Aerosol Generator: Generator Wt: 15500gr, Aerosol agent Wt: 2000gr, Discharge time: 15-20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-2000TS	FP-2000TS	FirePro	Condensed Aerosol Generator: Generator Wt: 15500gr, Aerosol agent Wt: 2000gr, Discharge time: 15-20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-3000	FP-3000	FirePro	Condensed Aerosol Generator: Generator Wt: 16300gr, Aerosol agent Wt: 3000gr, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-3000S	FP-3000S	FirePro	Condensed Aerosol Generator: Generator Wt: 16300gr, Aerosol agent Wt: 3000gr, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-3000T	FP-3000T	FirePro	Condensed Aerosol Generator: Generator Wt: 16300gr, Aerosol agent Wt: 3000gr, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-3000TS	FP-3000TS	FirePro	Condensed Aerosol Generator: Generator Wt: 16300gr, Aerosol agent Wt: 3000gr, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-4200	FP-4200	FirePro	Condensed Aerosol Generator: Generator Wt: 23600gr, Aerosol agent Wt: 4200gr, Thermal activation, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	15/02/2024
FP-4200S	FP-4200S	FirePro	Condensed Aerosol Generator: Generator Wt: 23600gr, Aerosol agent Wt: 4200gr, Thermal activation, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	15/02/2024
FP-4200T	FP-4200T	FirePro	Condensed Aerosol Generator: Generator Wt: 23600gr, Aerosol agent Wt: 4200gr, Thermal activation, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-4200TS	FP-4200TS	FirePro	Condensed Aerosol Generator: Generator Wt: 23600gr, Aerosol agent Wt: 4200gr, Thermal activation, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016



Certification Manager



global-mark®

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
FP-5700	FP-5700	FirePro	Condensed Aerosol Generator: Generator Wt: 26400gr, Aerosol agent Wt: 5700gr, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-5700S	FP-5700S	FirePro	Condensed Aerosol Generator: Generator Wt: 26400gr, Aerosol agent Wt: 5700gr, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-5700T	FP-5700T	FirePro	Condensed Aerosol Generator: Generator Wt: 26400gr, Aerosol agent Wt: 5700gr, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-5700TS	FP-5700TS	FirePro	Condensed Aerosol Generator: Generator Wt: 26400gr, Aerosol agent Wt: 5700gr, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
C20BR, C20BRSS	C20BR, C20BRSS	FirePro	Mounting bracket for 20 gr model	6/03/2026
C4080BRS1 / C4080BRS2 / C4-80BR / C1-2-5ABS	C4080BRS1 / C4080BRS2 / C4-80BR / C1-2-5ABS	FirePro	Mounting bracket, for 40 gr and 80 gr models	1/11/2025
C1-2-5ABS/C1-2-5RBR / C1-2-5RB / C1-2-5AS / C-1-2-5U	C1-2-5ABS/C1-2-5RBR / C1-2-5RB / C1-2-5AS / C-1-2-5U	FirePro	Mounting bracket for 100, 200 & 500 gr models	1/11/2025
B122030BRKT / B122030BRKT/A / BABRKTSWA / BABRKT / BTMBR1	B122030BRKT / B122030BRKT/A / BABRKTSWA / BABRKT / BTMBR1	FirePro	Mounting bracket for 1200, 2000 & 3000 gr models	1/11/2025
B57BRKT/ B57BRKT/C/ B57RKTSWA / BABRKT / BTMBR1	B57BRKT/ B57BRKT/C/ B57RKTSWA / BABRKT / BTMBR1	FirePro	Mounting bracket for 4200 and 5700 gr models	1/11/2025
Model 08451	Model 08451	Fire Safety Equipment	Control panel - Manual Rev 1.3	12/06/2018

Comments:

Compliance applies to Clause 6.3.3.5 Aerosol.

Australian & New Zealand Agent: Fire Safety Equipment Pty Ltd - Product may also have the Global-Mark ID # 103334

End of the document



Certification Manager

Jane Hoban