



A DIVISION OF GETZ FIRE EQUIPMENT

**Getz Equipment Innovators
Part No.: 3G0045
Dry Chem Reclaim Assembly**



2320 Lakecrest Drive, Pekin, Illinois 61554
Telephone: 888-747-4389 Fax: 309-495-0625
Website: www.getzequipment.com

Limited Warranty

Products manufactured by Getz Equipment Innovators (with exception of electrical products or components) will be free from defects for a period of one year from shipment date. Electrical products and/or components used in manufactured products will have a (6) month warranty from shipment date. During the warranty period, customers who experience any manufacture-related service issues with our products, the product may be returned for repair or replacement. Customer must contact Getz Equipment for approval prior to any product return. Notwithstanding the foregoing, the limited warranty set forth shall be immediately void of customer uses any replacement parts other than those provided by Getz Equipment Innovators. The warranty does not cover normal wear and tear items, defects resulting from modification, alteration, misuse, exposure to corrosive conditions, extremely high temperatures, improper installation or maintenance. Warranties on component items not manufactured by Getz Equipment Innovators are provided by others whose warranty, evaluation and judgment will be final.

All implied warranties, including, but not limited to, warranties of fitness for purpose and merchantability, are limited to the time periods as stated above. In no event shall Getz Equipment Innovators be liable to incidental or consequential damages. Some states do not allow limitations on how long an implied warranty lasts or the exclusions or limitation of incidental or consequential damages, so that the above limitations or exclusions may not apply to you. Getz Equipment Innovators neither assumes nor authorizes any representative or other person to assume for it any obligation or liability other than as expressly set forth herein.

Mobile Service Vehicles:

The warranty does not cover:

- Defects in the chassis and or power unit
- Defects in separately manufactured products not produced by Getz Equipment Innovators
- Deterioration due to normal wear, tear, and exposure
- Repairs made necessary by negligent use, misuse, abuse, loading the service vehicle beyond its gross vehicle weight limitations, accident, acts of God, or other contingencies beyond the control of Getz Equipment Innovators.
- Repairs deemed necessary by reason of the failure to follow ordinary maintenance procedures.
- Repairs deemed necessary by reason of alterations done without Getz Equipment Innovators' written approval.

Warranty Service:

- All warranty repairs will be performed by Getz Equipment Innovators in Pekin, IL, unless otherwise authorized by Getz Equipment Innovators.

Freight:

- Getz Equipment Innovators will not be liable for shipping or transportation charges to or from customer's location.

This warranty gives you specific legal rights, and you may also have other rights which vary from state to state. To obtain performance to the obligation of the warranty, write to Getz Equipment Innovators, 2320 Lakecrest Drive, Pekin IL 61554, USA for instructions.

Getz Equipment Innovators Dry Chem Reclaim Assembly

Table of Contents

Page

| | | |
|---|-------|--------------------------------|
| 2 | | Getz Dry Chem Reclaim Assembly |
| 3 | | Parts List |

Dry Chem Reclaim Assembly (Part No. 3G0045)

Operation:

Wear safety glasses at all times while using this product. The dry chemical reclaim assembly is shipped manufactured and ready to install. With the band clamp assembly removed place the bucket filter over a clean, dry 5-gallon pail. The filter should be pulled down evenly around the bucket. Install the band clamp around the bucket, filter and plastic lid making sure both the lid and bucket are fully clamped. You are now ready to discharge extinguishers into the bucket.

With the ball valve closed, discharge a small amount of chemical into the discharge assembly. Verify the chemical discharged is the desired chemical. Once the chemical type has been verified open the ball valve and discharge the remaining chemical from the extinguisher.


- *NOTICE** –
- 1. The dry chemical reclaim assembly is able to reclaim 40 lbs of chemical in a 5-gallon pail.**
 - 2. Do not discharge cartridge operated fire extinguishers into the dry chemical reclaim assembly.**
 - 3. Do not discharge Amerex high performance fire extinguishers into the dry chemical reclaim assembly.**

Once 40 lbs of chemical has been discharged into the pail remove the clamp and assembly. Immediately put a new tamper proof lid on the pail for storage or transport. Secure the lid with a rubber mallet. The reclaim assembly can now be put on the next 5-gallon pail for chemical recovery.

Maintenance:

- CLEAN FILTER WEEKLY
- REPLACE FILTER EITHER ONCE A YEAR OR AFTER FILLING 50 PAILS OF CHEMICAL, WHICH EVER COMES FIRST

PARTS LIST



| ITEM NO. | PART NUMBER | DESCRIPTION |
|----------|-------------|-------------------------|
| 1 | 1G0208 | LEVER LOCK FOR BUCKET |
| 2 | 1G0211 | LID BUCKET REPLACEMENT |
| 3 | 1G0212 | BUCKET LID (DISCHARGE) |
| 4 | 1G0225 | BUCKET FILTER |
| 5 | 1G51428 | HUB MEYER $\frac{3}{4}$ |
| 6 | 1G51789 | DISCHARGE SCREEN |
| 7 | 3G58545 | DISCHARGE ASSEMBLY |