

VEHICLE PROTECTION

CERTIFICATION

CLIENT NAME

Vehicle Make / Model

Risk Area

Classes of Fire
 Class A
 Class B
 Class E
 Class D
 Class F

STREAM (m)

GROSS DIMENSIONS (All in Meters)
Length: x Width: x Height: **Enter VOLUME** = m³

Actual Leakage Measurement - M² =

Leakage Allowance without additional Agent = m²

GROSS Volume used for Calculation = m³

PRIMARY AGENT DISCHARGE g

Secondary Agent Discharge g

Model	L2 (mm)	L3 (mm)	Stream Length (mm)	Effective Agent Qty	Concentration		Primary Quantity	Secondary Quantity
					Primary	Secondary		
FP-0020	0	100	300	20	-	-	-	-
FP-0040	0	100	1200	40	-	-	-	-
FP-0080	0	100	2000	80	-	-	-	-
FP-0100	0	100	1000	100	-	-	-	-
FP-0200	100	300	1500	200	-	-	-	-
FP-0500	200	500	2500	500	-	-	-	-
FP-1200	200	1200	3500	1,200	-	-	-	-
FP-2000	200	1200	3500	2,000	-	-	-	-
FP-3000	700	1700	4000	3,000	3,000	-	1	-
FP-5700	800	1800	8000	5,700	-	-	-	-

Total Concentration	3,000	-
Required Concentration	2,982	-
% Required Concentration	100%	

- Design Calculation has been Confirmed
- FirePro Units have suitable STREAM length for Risk Area Coverage
- Leakage compensation made in Primary Discharge
- Additional HOLD time Required for the risk

Aust.Std Design Notes

CALCULATION OF VOLUME : Calculation is based on Gross Volume with NO deductions for any Objects that occupy volume within the protected space. The concentration of Aerosol, and leakage allowances is based on Tests conducted in 2010 with Hughes Associates Europe. AS 5062.

Minimum Extinguishing Factors (mef) **145 X 1.3 = 189**

- L2 is the thermal clearance required where the temperature of the discharge is less than 200° C
- L3 is the thermal clearance required where the temperature of the discharge is less than 75° C
- Vehicle Systems are compliant to AS 5062
- FirePro Generators should be aimed at the items likely to be involved in the fire.

APPROVED

Prepared By: Company:

RECOMMENDED CONTROL EQUIPMENT
VSS Panel FP-08451 - Voltage: 24vDC
Cable : 40m