

Item	Description	Quantity	Agent/Distributor	Model/Part No.	OEM1	Power Supply Rating (A)	Battery Charger Rating (A)	Quiescent Current (mA) per device	Alarm current (mA) per device	Fixed Service Life (years)	Nominated Service Life (years)	Installed to AS 1670.1	Installed to AS 4487	Maintenance Requirements to AS 1851
1	Fire Indicator Panel (FIP) - 2 zone	1	Fire Safety Equipment	JP118876	Incite	3	0.7	65	105	NS ⁽¹⁾	10 ⁽²⁾	Y		Section 7
4	Photo Electric Smoke Detector	3	Fire Safety Equipment	JP118880	Hochiki			0.04	80	NS ⁽¹⁾	10 ⁽²⁾	Y		Section 7
5	Thermal detector Fixed Temp.60°C	3	Fire Safety Equipment	JP118881	Hochiki			8	28	NS ⁽¹⁾	5 ⁽²⁾	Y		Section 7
6	Sign - System Inoperative	2	Fire Safety Equipment	JP119294	Incite			20	140	NS ⁽¹⁾	10 ⁽²⁾		Y	Section 7
7	Sign - Fire Alarm Do Not Enter	2	Fire Safety Equipment	JP119295	Incite			20	140	NS ⁽¹⁾	10 ⁽²⁾		Y	Section 7
8	Sign - Fire Alarm Evacuate Area	1	Fire Safety Equipment	JP119293	Incite			20	140	NS ⁽¹⁾	10 ⁽²⁾		Y	Section 7
9	Local Control Station/Remote Status Unit	1	Fire Safety Equipment	JP128992	Incite			33	60	NS ⁽¹⁾	10 ⁽²⁾		Y	Section 7
10	Thermal fuse	1	Fire Safety Equipment	JP128996	FSE					NS ⁽¹⁾	10 ⁽²⁾		Y	Section 7
12	Sounder	3	FirePro Finland	JP119296	Fulleon				85	NS ⁽¹⁾	10 ⁽²⁾	Y		Section 7
13	Sounder/Strobe	3	FirePro Finland	JP128952	Fulleon				85	NS ⁽¹⁾	10 ⁽²⁾	Y		Section 7
14	Aerosol Generator – 3000g	1	FirePro Finland	JP128874	Fire Pro Finland					15	10 ⁽²⁾		Y	Section 7
15	Aerosol Generator – 2000g	2	FirePro Finland	JP118885	Fire Pro Finland					15	10 ⁽²⁾		Y	Section 7
16	Aerosol Generator – 1200g	1	FirePro Finland	JP118884	Fire Pro Finland					15	10 ⁽²⁾		Y	Section 7
17	Battery – 12v 10Ah	2	FirePro Finland	JP128993	Yuasa					1	1	Y		Section 7