

# Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

Company Name	<b>Fire Safety Equipment Pty Ltd</b>	Client ID	<b>103334</b>
Company Other Name		Type of Certification	<b>Product Certification; System 5</b>
Certification Standard	<b>AS 4487-2013 : Condensed aerosol fire extinguishing systems - Requirements for system design installation and commissioning and test methods for components</b>		
Scheme	<b>No Scheme</b>		
Certification Review Date	<b>13/10/2015</b>	Certification Expiry Date	<b>13/10/2020</b>
Certificate Issue Date	<b>8/12/2015</b>	Certificate Last Update Date	<b>9/04/2017</b>

**APPROVED COMPANY/SITE ADDRESS(ES):**

**2A Staple Street Seventeen Mile Rocks 4073 QLD Australia**

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



**Certification Manager**



Unique Certificate Code: **22376215149F9864CA2580FB00244E13**

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005





**Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:**  
*In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).*

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
B122030BRKT, B122030BRKT/A	B122030BRKT, B122030BRKT/A	FirePro	Mounting bracket for 1200, 2000 & 3000 gr models	13/10/2016
B57BRKT / B57BRKTC	B57BRKT / B57BRKTC	FirePro	Mounting bracket for 4200 and 5700 gr models	13/10/2016
C1-2-5ABS/C1-2- 5RBR / C1-2-5RB / C1-2-5AS / C-1-2SU	C1-2-5ABS/C1-2-5RBR / C1-2-5RB / C1-2-5AS / C-1-2SU	FirePro	Mounting bracket for 100, 200 & 500 gr models	13/10/2016
C20BR	C20BR	FirePro	Mounting bracket for 20 gr model	13/10/2015
C4080BRS1 / C4080BRS2 / C4- 80BR	C4080BRS1 / C4080BRS2 / C4-80BR	FirePro	Mounting bracket, for 40 gr and 80 gr models	13/10/2016
FP-100S	FP-100S	FirePro	Condensed Aerosol Generator: Generator Wt: 1840gr, Aerosol agent Wt: 100gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-1200	FP-1200	FirePro	Condensed Aerosol Generator: Generator Wt: 10900gr, Aerosol agent Wt: 1200gr, Discharge time: 10 - 15 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-1200S	FP-1200S	FirePro	Condensed Aerosol Generator: Generator Wt: 10900gr, Aerosol agent Wt: 1200gr, Discharge time: 10 - 15 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-1200T	FP-1200T	FirePro	Condensed Aerosol Generator: Generator Wt: 10900gr, Aerosol agent Wt: 1200gr, Thermal Activation, Discharge time: 10 - 15 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-1200TS	FP-1200TS	FirePro	Condensed Aerosol Generator: Generator Wt: 10900gr, Aerosol agent Wt: 1200gr, Thermal Activation, Discharge time: 10 - 15 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-2000	FP-2000	FirePro	Condensed Aerosol Generator: Generator Wt: 15900gr, Aerosol agent Wt: 2000gr, Discharge time: 10 - 15 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-2000S	FP-2000S	FirePro	Condensed Aerosol Generator: Generator Wt: 15900gr, Aerosol agent Wt: 2000gr, Discharge time: 10 - 15 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-2000T	FP-2000T	FirePro	Condensed Aerosol Generator: Generator Wt: 15900gr, Aerosol agent Wt: 2000gr, Thermal activation, Discharge time: 10 - 15 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-2000TS	FP-2000TS	FirePro	Condensed Aerosol Generator: Generator Wt: 15900gr, Aerosol agent Wt: 2000gr, Thermal activation, Discharge time: 10 - 15 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-200S	FP-200S	FirePro	Condensed Aerosol Generator: Generator Wt: 1840gr, Aerosol agent Wt: 200gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015



**Certification Manager**

*Hevi Ndha*



global-mark®

Model Identification	Model Name	Brand Name	Product Description/Attributes	Date Approved
FP-20SE	FP-20SE	FirePro	Condensed Aerosol Generator: Generator Wt: 310gr, Aerosol agent Wt: 20gr, Stainless steel housing, Discharge time: 5 - 10 Secs, Two direction outlet, Fire Class: A, B, E	13/10/2015
FP-20T	FP-20T	FirePro	Condensed Aerosol Generator: Generator Wt: 310gr, Aerosol agent Wt: 20gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-3000	FP-3000	FirePro	Condensed Aerosol Generator: Generator Wt: 16700gr, Aerosol agent Wt: 3000gr, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-3000S	FP-3000S	FirePro	Condensed Aerosol Generator: Generator Wt: 16700gr, Aerosol agent Wt: 3000gr, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-3000T	FP-3000T	FirePro	Condensed Aerosol Generator: Generator Wt: 16700gr, Aerosol agent Wt: 3000gr, Thermal activation, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-3000TS	FP-3000TS	FirePro	Condensed Aerosol Generator: Generator Wt: 16700gr, Aerosol agent Wt: 3000gr, Thermal activation, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-40S	FP-40S	FirePro	Condensed Aerosol Generator: Generator Wt: 610gr, Aerosol agent Wt: 40gr, Discharge time: 5 - 10 Secs, Two direction outlet, Fire Class: A, B, E	13/10/2015
FP-40T	FP-40T	FirePro	Condensed Aerosol Generator: Generator Wt: 610gr, Aerosol agent Wt: 40gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-4200T	FP-4200T	FirePro	Condensed Aerosol Generator: Generator Wt: 25000gr, Aerosol agent Wt: 4200gr, Thermal activation, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-4200TS	FP-4200TS	FirePro	Condensed Aerosol Generator: Generator Wt: 25000gr, Aerosol agent Wt: 4200gr, Thermal activation, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016
FP-500S	FP-500S	FirePro	Condensed Aerosol Generator: Generator Wt: 3340gr, Aerosol agent Wt: 500gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-5700	FP-5700	FirePro	Condensed Aerosol Generator: Generator Wt: 26400gr, Aerosol agent Wt: 5700gr, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-5700	FP-5700	FirePro	Condensed Aerosol Generator: Generator Wt: 26400gr, Aerosol agent Wt: 5700gr, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-5700	FP-5700	FirePro	Condensed Aerosol Generator: Generator Wt: 26400gr, Aerosol agent Wt: 5700gr, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-5700S	FP-5700S	FirePro	Condensed Aerosol Generator: Generator Wt: 26400gr, Aerosol agent Wt: 5700gr, Discharge time: 15 - 20 Secs, One direction outlet, Fire Class: A, B, E	13/10/2015
FP-80S	FP-80S	FirePro	Condensed Aerosol Generator: Generator Wt: 870gr, Aerosol agent Wt: 80gr, Discharge time: 5 - 10 Secs, Two direction outlet, Fire Class: A, B, E	13/10/2015
FP-80T	FP-80T	FirePro	Condensed Aerosol Generator: Generator Wt: 870gr, Aerosol agent Wt: 80gr, Discharge time: 5 - 10 Secs, One direction outlet, Fire Class: A, B, E	13/10/2016

**Comments:**

Compliance applies to Clause 6 of AS4487.



**Certification Manager**

*Hevi Ndha*



global-mark®

End of the document



Certification Manager

*Henri Adams*