



- NOTES
1. IP1P42
 2. MAIN BUSBAR-4P-2X40X10 BARE COPPER AND FULLY INSULATION
 3. PE SPEC-40X10 BARE COPPER
 4. COLOR: RAL 9010
 5. INCOMING&OUTGOING-CABLE INCOMING&OUTGOING FROM BOTTOM/TOP

FirePro fire suppression system suggested location layout per cabinet
 Fire Safety Equipment
 Auxiliary Point MCC

TAG NO.	1137-MCC-2301
TOTAL SHEET NO.	2
TOTAL	6
SUB SHEET NO.	1
SUBTOTAL	5
ABB CONTRACT NO.	PM006436-01
ABB DRAWING NO.	1TNR006436D2101
REV.	0
FUNCTION	

GENERAL ARRANGEMENT
ABB
 XIAMEN L.V. EQUIPMENT CO. LTD.

JACOBS DRAWING NUMBER	CW211715-8001-0048-R1
OWNER/PROJECT	OYU TOLGOI PROJECT
SHAFT 2 AUXILIARY HOIST	
DESIGNED BY	JianDe Xu
CHECK DESIGN	Arong Zhang
APPROVAL DATE	
PROJECT MANAGER	
CLIENT	
SCALE	25
DATE	1137-62-8063
REV.	0

Oyu Tolgoi
 OYU TOLGOI LLC
 ОЮУ ТӨЛГӨЙ ХХК

DESIGNED BY: JianDe Xu
 CHECK DESIGN: Arong Zhang
 PROJECT NO: 1137-MCC-2301
 CONTRACT NO: 1137-MCC-2301
 DRAWING SIZE: 25
 PROJECT MANAGER: [Blank]
 CLIENT: [Blank]

REV.	DATE	REVISION DESCRIPTION	DES. CHK.	APPROVED	REFERENCE DRAWING No.	REFERENCE DRAWINGS
0	12/22/19	Final Certified			1137-62-8017	1137-MCC-2301 SINGLE LINE DIAGRAM 1137-MCC-2301 SCHEMATIC DIAGRAM
1	02/28/19	First issued for approval				
2	12/20/19	Updated as per comments				