


Low Voltage Switchgear
 3/TN-C 400V/50Hz In=1700A Ik=50kA IP41




Total length: 3440

JACOBS		Contractor/Supplier/Vendor Technical Document and Drawing Review for SNI1809AO - OT Underground Project		
<input checked="" type="checkbox"/>	1	Reviewed with No Comments. (Construction/Fabrication may Proceed)		
<input type="checkbox"/>	2	Reviewed with Minor Comments. Revise and resubmit "Final Version" incorporating comments. (Construction/Fabrication may proceed thereafter)		
<input type="checkbox"/>	3	Rejected with Major Comments. Correct and resubmit "Final Review" incorporating comments. (DO NOT PROCEED with Construction or fabrication)		
<input type="checkbox"/>	4	Not Reviewed - Received For Information Only. No further submission is required.		
<input type="checkbox"/>	5	Received Certified/Equipment Package Vendor Document. Received As Built - Contractor Document.		
<input type="checkbox"/>	6	Cancelled.		
<input type="checkbox"/>	YES	NO	Submit Certified Document.	
Responsible Engineer		Name: Zamani, Payam Signature: [Signature] Date: 2019.01.09.09.07.19 +10100		
Equipment Tag No.		1137-MCC-2101		
Client Document No.		1137-65-G2-8029		
Jacobs Document No. and Revision		CW2111715-B001-0020_R2		
AUTHORIZATION TO PROCEED DOES NOT RELIEVE THE VENDOR/CONTRACTOR OF ANY RESPONSIBILITY, OBLIGATION OR LIABILITY UNDER THE PURCHASE ORDER/CONTRACT. NO RESPONSIBILITY IS ASSUMED BY JACOBS FOR CORRECTNESS OF DIMENSIONS OR DETAILS. SHOP DRAWINGS ARE ACCEPTED AS FOR INFORMATION ONLY (NOT REVIEWED). VENDOR/CONTRACTOR IS FULLY RESPONSIBLE FOR SHOP DRAWINGS.				

Legend for FirePro Generator Suggested Location

For the size of the generator, refer to Equipment Schedule
 Direction of Mounting in each cabinet



FirePro Fire Suppression System Suggested Location Layout Per Cabinet Fire Safety Equipment SERVICE HOIST MCC

Based on	09-05-18/9-16/9-16	Prepared	09-05-18	K-E LINDKVIST	FRONT LAY-OUT	1137-65-G2-8029
		Approved	09-05-18	C ÅSTRÖM	OYU TOLGOI PROJECT	
					ABB AB/MINING	
					ABB AB	
					LV Systems	
						Resubmitt. OK Revind. B Lang. Sheet 1
						Cont. -
						1TSX102827-CA