

AUKI Exchange.

Pre-engineered System design -

- Volume – 82.3 cu mtrs.
- Certification - UL2775/AS4487 certification design calculation
- Design concentration 8,989grams
- Total concentration recommended – 9,000 -100%
- Generators - 3 x 3000g

