

Central Exchange - Battery & Rectifier Rooms.

- Volume – 231 cu mtrs.
- Certification - UL2775/AS4487 certification design calculation.
- Design concentration 25,225 grams
- Total concentration recommended – 25,800 grams -102%
- Generators - 4 x 5700g generators & 1 x 3000g

