

Central Exchange – MDF Room

- Volume – 405 cu mtrs.
- Certification - UL2775/AS4487 certification design calculation.
- Design concentration 44,226 grams
- Total concentration recommended – 51,300 grams -115%
- Generators - 9 x 5700g generators
- Stream length 8mtrs for each 5700g generator 28kg each