

Central Exchange - Switchroom

- Volume – 231 cu mtrs.
- Certification - UL2775/AS4487 certification design calculation.
- Design concentration 25,225 grams
- Total concentration recommended – 25,800 grams -102%
- Generators - 4 x 5700g generators & 1 x 3000g generator.
- Stream length 8mtrs for each 5700g generator 28kg each & 4M for each 3000g.