

Risk 1– King George Exchange Honiara.

Pre-engineered System design -

- Volume – 168cu mtrs.
- Certification - UL2775/AS4487 certification design calculation.
- Design concentration 18,346 grams
- Total concentration recommended – 19,100 grams -104%
- Generators - 3 x 5700g generators & 1 x 2000

