

Munda Office Equipment Room-

- Volume – 65.04 mtrs.
- Certification - UL2775/AS4487 certification design calculation
- Design concentration 7,103grams
- Total concentration recommended – 8,700grams -122%
- Generators - 1 x 5700g & 1 x 3000g

