

Noro Redundant Core Building Equipment room

- o Volume – 47.5cu mtrs.
- o Certification - UL2775/AS4487 certification design calculation
- o Design concentration 5,188grams
- o Total concentration recommended – 5,700grams -109%
- o Generators - 1 x 5700g
- o Stream length 8mtrs for 5700g



Noro Redundant Core Building Storage room-

- Volume – 41.46cu mtrs.
- Certification - UL2775/AS4487 certification design calculation
- Design concentration 4,527grams
- Total concentration recommended – 5,700grams -125%
- Generators - 1 x 5700g

