

Noro Redundant Core Building MDF room

- o Volume – 27.9cu mtrs.
- o Certification - UL2775/AS4487 certification design calculation
- o Design concentration grams-3040g
- o Total concentration recommended – 4,000grams -131%
- o Generators - 2 x 2000g
- o Stream length 3.5mtrs for 2000g generator

