

Vivaya Exchange Equipment room & Battery Room.

Pre-engineered System design -

- Volume – 98 cu mtrs.
- Certification - UL2775/AS4487 certification design calculation.
- Design concentration 10,702 grams
- Total concentration recommended – 12,000 grams -112%
- Generators - 2 x 3000g & 3 x 2000g

