



Note:

1. Fire extinguisher is completed according to the standard GB4351-1984. All tests shall meet the requirements of standard.
2. All accessories for the fire extinguisher shall be inspected before assembly and be ensured they are free of defect such as damage crack.
3. Extinguishing agent: 40% ABC Powder (yellow color) 8 ± 0.16 KG.
4. Fire ext. assembly: Filled with powder, but without Nitrogen.
5. Package: 2PCS/CTN 340x170x625 CM/CTN
6. Stamp on the foot ring:

ECCO Australia MASA TOTAL xx.xKG PS 1.4MPa PE 3.5MPa FAB XX/11 K 203365 (~204164)

9	P8-ZX	Carton
8	T02-01-01	Wall Bracket
7	T11-02-02	Seal
6	T12-xx	Gauge
5	T08-01-03	Plastic black Belt
4	T16-12-485	Dip tube
3	P8-UQ	cylinder
2	T15-P8-01	Hose
1	YF0205-00D	Valve

MODEL 800 8KG 40% ABC Fire Ext.