


Notes:
 Cylinder - Min Burst Pressure 5.0 MPa
 Cylinder - Test Pressure 1.8 MPa
 Valve - Leak Test (30 Sec) 1.5 MPa
 Valve - Test Pressure (60 Sec) 2.7 MPa
 Powder Coated (RAL 3000) Min 0.07mm
 All measurements shown are in mm
 All Bracket Back Holes are 6mm



Advocavi S.A.				
Drawn By PM	Approved By	Title 1.0 kg ABC Fire Extinguisher	Drawing No NF1S	Rev. B
Scale	Date 20-10-17			