

Vessel Name

Risk Area

Constructed From

Class A
 Class B
 Class E
 Class D
 Class F

VESSEL Length Meters

GROSS DIMENSIONS

Length x Width x Height = m³
 Actual Leakage Measurement - M² = m²

Leakage Allowance without additional Agent = m²

GROSS Volume used for Calculation = m³

PRIMARY AGENT DISCHARGE = g

Secondary Agent Discharge =

Model	L2 (mm)	L3 (mm)	Stream (mm)	Agent Qty	Concentration		Primary Quantity	Secondary Quantity
					Primary	Secondary		
FP-0020	0	100	300	20	-	-		
FP-0040	0	100	1200	40	-	-		
FP-0080	0	100	2000	80	-	-		
FP-0100	0	100	1000	100	-	-		
FP-0200	100	300	1500	200	-	-		
FP-0500	200	500	2500	500	-	-		
FP-1200	200	1200	3500	1,200	-	-		
FP-2000	200	1200	3500	2,000	-	-		
FP-3000	700	1700	4000	3,000	3,000	-	1	
FP-5700	800	1800	8000	5,700	-	-		

Total Concentration	3,000	-
Required Concentration	2,460	-
% Required Concentration	121%	

- Design Calculation has been Confirmed
- FirePro Units have suitable STREAM length for Risk Area Coverage
- Leakage compensation made in Primary Discharge
- Additional HOLD time Required for the risk

Marine Design Notes - Vessels to 24 m

Pre-Engineered Design Calculation

CALCULATION OF VOLUME : Volume is Gross Volume with NO deductions for Engine Machinery. The calculation based on the Maritime Coast Guard Agency(UK) MS22/3/910. This can only be used for vessels less than 24 metres Registered Length. AMSA.

Minimum Extinguishing Factors (mef) 82 X 1 = 82

- L2 is the thermal clearance required where the temperature of the discharge is less than 200° C
- L3 is the thermal clearance required where the temperature of the discharge is less than 75° C

APPROVED

Prepared By: Company: